



PAVUS, a.s.

AUTHORIZED BODY 216
NOTIFIED BODY 1391
ACCREDITED CERTIFICATION BODY FOR
PRODUCTS N° 3041

Branch: FIRE TESTING LABORATORY
VESELÍ NAD LUŽNICÍ
Čtvrť J. Hybeše 879
CZ 391 81 Veselí nad Lužnicí
Czech Republic

Address:

Prosecká 412/74, 190 00 Praha 9 – Prosek
Tel.: 286 019 587 Fax: 286 019 590
E-mail: mail@pavus.cz, http://www.pavus.cz

Phone: +420 381 477 418

Fax: +420 381 477 419

Mail to: veseli@pavus.cz

REACTION TO FIRE CLASSIFICATION REPORT

**The object of
classification:**

*Construction products excluding floorings and
linear pipe thermal insulation products in
accordance with CSN EN 13501-1, clause 11*

Issue number:

PK1-01-17-029-E-0

Product name and type:

Textile Softimage Contrast Art. No. 599150150

Sponsor:

PONGS TECHNICAL TEXTILES GmbH
Bahnhofstraße 21
07919 Pausa - Mühltruff
Germany

Issuing organization:

PAVUS, a.s.
Authorized Body 216
Notified Body 1391
Accredited certification body for products No 3041
- Accreditation issued by Czech Accreditation Institute, Public
Service Company
- Certificate of Accreditation N° 353/2016
Prosecká 412/74
190 00 PRAHA 9
Order no. Z210160285

Date of issue:

2017-07-11

Copies in total:

4

Copy number:

4

Pages in total:

4



1. INTRODUCTION

- 1.1. This Classification Report specifies classification method for the product *Textile Softimage Contrast* in conformity with the procedures set forth in CSN EN 13501-1+A1: 2010.
- 1.2. This Classification Report has 4 pages and it can be used or reproduced as a whole only.

2. DETAILED INFORMATION ON THE ELEMENT TO BE CLASSIFIED

2.2. General

The product – *Textile Softimage Contrast* is made by the company PONGS TECHNICAL TEXTILES GmbH, Bahnhofstraße 21, 07919 Pausa - Mühltruff, Germany. It is used as support for digital print.

2.3. Product description

Thickness: 0.2 mm (measure at ATL)
 Mass per unit area: 0.350 kg/m²
 Composition: PES, PU coating

3. REPORTS AND RESULTS IN SUPPORT OF CLASSIFICATION

3.1 Reports

Name of the Laboratory Address Accreditation number:	Name of sponsor of the Test Report	Report number Date of issue	Test method
PAVUS, a. s. Veseli nad Luznici ATL No. 1026	PONGS TECHNICAL TEXTILES GmbH technika, spol. s r.o. Bahnhofstraße 21 07919 Pausa - Mühltruff Germany	Pr-17-1.067 2017-04-10	ČSN EN 13823:2010
		Pr-17-1.066 2017-07-11	ČSN EN ISO 11925-2:2011

3.2 Results

Test method	Parameter	Number of tests	Results	
			Continuous parameter-mean	Compliance with parameters
CSN EN 13823	<i>FIGRA_{0.2 MJ} (W/s)</i>	3	0.0	≤ 120
	<i>THR_{600s} (MJ)</i>		0.4	≤ 7.5
	<i>LFS < edge of specimen</i>		-	yes
	<i>SMOGRA (m²/s²)</i>		0.0	≤ 30
	<i>TSP_{600s} (m²)</i>		35.5	≤ 50
	<i>non-occurring of flaming droplets/particles</i>		-	yes
CSN EN ISO 11925 - 2	<i>F_s ≤ 150 mm up to 60 s</i>	6	-	no
Surface exposure	<i>Filter paper non-ignition</i>	6	-	no
CSN EN ISO 11925 - 2	<i>F_s ≤ 150 mm up to 60 s</i>	6	-	no
Edge exposure	<i>Filter paper non-ignition</i>	6	-	no

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1. Classification references

This classification was carried out in conformity with CSN EN 13501-1+A1: 2010.

4.2 Classification

The product - *Textile Softimage Contrast* - in conformity with its behaviour under the reaction-to-fire tests, is classified as follows:

Reaction to fire class: B – s1, d0

4.3. The field of application

This classification applies for the following parameters of the product:
Parameters noticed in the clause 2.2.

This classification applies for the following end-use applications:
Free placed product.

5. RESTRICTIONS

This Classification Report does substitute neither the type approval nor the product certificate.

This classification is valid, unless the conditions, under which it was issued, have been changed. The sponsor may request the issuing authority to review the influence of changes to the classification validity.

Therefore the Testing Laboratory has no part in preparing the product specimens for tests although the Laboratory provides, on manufacturer's request, a suitable certification that the Laboratory took part in monitoring the preparation of specimens for tests.

Elaborated by:



Ing. Ondřej FOHL
Fire testing laboratory

PAVUS, a. s.
Autorizovaná osoba AO 216
Pobočka
391 81 Veselí nad Lužnicí

Approved by:



Ing. Jaroslav DUFEK

